

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. KDLL/26/92

Date: - 11/08/2026

It is certified that an inspection team headed by Meghna Baruah, AE (PHE)

(Name of Officers with designation) from PHED, Guwahati Division NO. 1

inspected the ST ANTHONY'S SCHOOL, ABHOYPUR, North Guwahati (Name and

Address of the school) on 07/08/2026 (date of inspection) and on the basis of Water

Test Report (attached) bearing No. KDLL/26/92, date 11-08-2026

of District Level Laboratory, Kamrup at (PHED LAB) certified that the

Parameter tested are safe range as ISO-17025 (name of school) has safe drinking water facilities for the students and members of the staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till August, 2027.

Signature with seal

Meghna Baruah
12.08.26

Name

Meghna Baruah,

Designation

Assistant Engineer (PHE)

Name & Address of the Officer/ Department

O/o Executive Engineer, Guwahati Division NO. 1

Bornunimaidam, Ghy-21

To

The, Principal

St, Anthony's, School.

Abhoypur, North Guwahati

(Name & Address of the institution)

In Charge
District Level Laboratory
Kamrup (PHE) Department
Guwahati-21

Note: the certificate is to be issued by authorized Officer/ PHED Lab/ local bodies.

**DISTRICT LEVEL LABORATORY (PHED), KAMRUP**

Address: Bamunimaidam, Guwahati- 21

Email ID: phe.kamrup@gmail.com

Test Report

ULR NO. TC1268426000000092

Customer Reference No. KDLL/26/92

LAB ID: 92

Customer Name & Address: ST ANTHONY'S SCHOOL, North Guwahati.

Sample Collection Date: 05/08/2026

Sample Collected By: Demos Boro

Sample Location: North Guwahati, Abhoypur

Date of Analysis Started: 10/08/2026

Issue Date: 11/08/2026

Temp: 26.5°C & Humidity: 48.8%

Test Sample: Boring (Filter)

Customer Contact No. 6838847064

Sample Received on Date: 05/08/2026

Quantity: 1 Liter

Sample Condition: Good condition at 4°C

Date of Analysis Completed: 11/08/2026

RES ULTS

Sr. No.	Parameter	Protocol Used	Results	IS: 10500:2012(Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Colour	IS: 3025 (Part 4): 2021	5	5	15	Hazen
2	Taste	IS: 3025 (part 8)	Agreeable	Agreeable	Agreeable	
3	Turbidity	IS: 3025 (Part 10): 2023	0	1	5	NTU
4	pH @ 25°C	IS: 3025 (Part 11): 2022	8.40	6.5 – 8.5	No relaxation	pH unit
5	TDS	IS: 3025 (Part 16): 2023	14	500	2000	mg/L
6	Chloride	IS : 3025 (Part 32): 2025	14.18	250	1000	mg/L
7	Total Alkalinity	IS: 3025 (Part 23): 2019	10	200	600	mg/L
8	Total Hardness	IS: 3025 (Part 21): 2019	12.6	200	600	mg/L
9	Calcium (as Ca)	IS: 3025 (Part 40): 2019	3.37	75	200	mg/L
10	Magnesium	APHA (24th Ed) 3500 Mg Method B (by calculation): 2023	1.02	30	100	mg/L
11	Total Iron	APHA 3500 24th Edition-3500- Fe Method B(Phenanthroline Method): 2023	0.021	1	No relaxation	mg/L
12	Free Residual Chlorine	IS 3025(Part 26)		0.2	1	mg/L
13	Arsenic	APHA 24th Edition-3500 Method B(silver Diethyldithiocarbamate Method): 2023		0.01	No relaxation	mg/L
14	Fluoride	APHA 24th Edition- 4500 F Method C(Electrode Method): 2023	0.142	1	1.5	mg/L
15	Nitrate	APHA 24TH Edition-4500-NO3 Method D(UV Screening Method): 2023	0.118	45	No relaxation	mg/L
16	Sulphate	IS 3025 (Part 24)/Sec1) (Turbidimetric Method): 2022	13.547	200	400	mg/L
17	Odour	IS 3025 (Part 5)	Agreeable	Agreeable	Agreeable	

Tested By: Edul Ali/Bikon Narzary

Notes:

- The results given above are related to the sample as received and tested in this laboratory. Reliability of sample lies with the sender.
- The test report cannot be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report cannot be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.
- BDL= Below Detective Level.

END OF TEST REPORT

Megha Baruah
Lab-in-charge
Kamrup DLI

In Charge
District Level Laboratory
Kamrup (PHE) Department
Guwahati-21

Authorized By:

Manash Pratim Kalita
Quality Manager
Kamrup DLI

QUALITY MANAGER
DLI(NABL), PHED, ASSAM
Bamunimaidam, Guwahati-21