



सत्यमेव जयते

GOVT. OF ASSAM  
OFFICE OF THE DIRECTOR  
FIRE AND EMERGENCY SERVICES, ASSAM  
PANBAZAR, GUWAHATI



Form - G

UBIN : 291/843463/AAATS5617F/8/2025

UAIN : FNESBNOCI/2026/00944

FIRE SAFETY CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN APPLICATION FOR FIRE NOC FOR ONE STORIED / MULTI-STORIED / HIGH RISE BUILDING UNDER ASSAM FIRE SERVICE RULE 1989 (FORM NO I)

Hazard Category: **Moderate Hazard**

This Fire Safety Certificate is issued to **St. Antonys School** on **13/05/2026** with reference to Compliance Report No. **Nil** dated **30/03/2026**

I here by certify that the building as per description below at **Dag No. 715 Patta No. 198 Mouza SILA SINDURI GHOPA Place North Guwahati , KAMRUP** has been inspected in respect of implementation of inbuilt Fire Fighting, Fire Prevention and Means of escape measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has no objection in its occupation/ utilization for the purpose of:

DETAILS OF APPROVED OCCUPATION

S. No.	Floor	Floor Area	Purpose of Utilization
1.	GROUND FLOOR	619 SQM, 418 SQM	SCHOOL
2.	FIRST FLOOR	619 SQM, 418 SQM	SCHOOL
3.	SECOND FLOOR	619 SQM, 418 SQM	SCHOOL
4.	THIRD FLOOR	418 SQM	SCHOOL

THIS FIRE SAFETY CERTIFICATE IS VALID UP TO **The Fire Safety Certificate shall remain valid until it is cancelled by the Competent Authority.**

Director/Deputy

Place of issue : **GUWAHATI**  
Date of issue : **13/05/2026**

**Director/Supdt. of Police  
cum F&ESA,  
Fire and Emergency  
Services, Assam,  
Panbazar, Guwahati.**

(Subject to Conditions mentioned here under)

**CONDITIONS :**

1. There should not be any change of Trade for which this License has been issued.
2. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
3. The fire fighting equipments should be in serviceable condition at all time
4. Water reservoir should always be kept full up to brim
5. The entrance and exit and the water reservoir should always be free from any obstruction/projection.
6. The Fire Safety Certificate is liable to be cancelled if the premises (for which the Fire Safety Certificate is granted) when inspected are not found conforming to the description and condition under which this Fire safety Certificate is granted.

**Director/Deputy  
Director/Supdt. of Police  
cum F&ESA,  
Fire and Emergency  
Services, Assam,  
Panbazar, Guwahati.**

